



NOTES:
 1. VACUUM BREAKER MUST BE INSTALLED ON HOSE BIBB (INCLUDING HOSE BIBBS WITH BUILT-IN ANTI-BACKFLOW DEVICES).

REV	DESCRIPTION	DATE
A	INITIAL RELEASE	09/13/2018
B	REVISED NOTES	09/13/2018
DRFT: SGP	CHK'D: BT	APPD: JK
SHEET 1 OF 1	DATE: 10/01/2018	

STANDARD TEMPORARY WATER CONNECTION CONSTRUCTION SITES DETAIL



City of Horseshoe Bay
 1 COMMUNITY DRIVE
 HORSESHOE BAY, TEXAS 78657
 830.598.9981
www.horseshoe-bay-tx.gov

SCALE: NONE
 WTR-TYP-008_STANDARD